




Please Note:
 Notifications of access denied must be turned off in Pure Access to prevent the history from getting inundated with rejected credential events

ISONAS R-1
 Wiegand
 Proximity
 Reader
 Mounted In
 Elevator Cab #1



Shields to
 Elevator common
 Ground

Cat5e/6 to PoE Switch



To next IPBridge Ground

To next IPBridge
 (Limit of 9 floors total)

IPB.ElevatorControl		
Dwg No:	Sheet 1	of 1
Date: 1-6-20	Drawn By: David Tamarchenko	Version: 1.00.04
		4750 Walnut Street Suite 110 Boulder, CO 80301 www.isonas.com