



<p><b>RC-03 Configuration:</b></p> <p>Enable REX Admit Latch Interval 5 Sec.</p>	<p><b>DS-160 Request to Exit Motion Sensor Configuration:</b></p> <p>Dip Switches (ON) 1,2,5,6, and 7 Dip Switches (OFF) 3,4,8,9, and 10</p>	<p><b>Altronix 6030 Multi Purpose Timer Configuration:</b></p> <p>SW1-Open for 12VDC Operation SW2-Open for Min. SW2-Closed for Sec.</p>	<p>Don't forget to calculate maximum current consumption of all equipment</p> <p>Do not exceed 600ma</p> <p>An auxilury power supply may be required depending on locking hardware</p>	<p>PowerNet RC Jumper Positions</p>  <p>RJ-45</p>
--	--	--	--	--

**RC-03.PoE.Strike.Rex.DSM.  
DoorHoldOpenOutput.  
DoorForcedOpenOutput**

Dwg No:	Sheet 1 of 1
Date: 5-14-19	Version: 1.00.00
Drawn By: David Tamarchenko	


 4750 Walnut Street Suite 110  
 Boulder, CO 80301  
 www.isonas.com