


<p><u>RC-03 Configuration:</u></p> <p>Enable REX Admit</p> <p>Latch Interval 5 Sec.</p>	<p><u>Altronix 6030 Multi Purpose Timer Configuration:</u></p> <p>SW1-Open for 12VDC Operation</p> <p>SW2-Open for Min. SW2-Closed for Sec.</p>	<p>Don't forget to calculate maximum current consumption of all equipment</p> <p>Do not exceed 600ma</p> <p>An auxiliary power supply may be required depending on locking hardware</p>	<p>PowerNet RC Jumper Positions</p>  <p>RJ-45</p>
---	---	---	--

<p align="center"><b>RC-03.RC-04.PoE.Strike.Rex.DSM.</b></p> <p align="center"><b>DoorHoldOpenOutput.</b></p> <p align="center"><b>DoorForcedOpenOutput.ReadinReadOut</b></p>		
<p>Dwg No:</p>	<p>Sheet 1</p>	<p>of 1</p>
<p>Date: 5-29-19</p>	<p>Drawn By: David Tamarchenko</p>	<p>Version: 1.00.00</p>
<p><b>ISONAS</b> PURE IP ACCESS CONTROL</p> <p>4750 Walnut Street Suite 110 Boulder, CO 80301 www.isonas.com</p>		