



Important – Read This First

- Always check with the local AHJ to make sure that your design meets code for the given address and occupancy
- Door #1 (Normally Locked) Door Status Outputs MUST be Magnetic Bond Sensors
- Door #2 (Normally Unlocked) Door Status Outputs MUST be Door Position Switches

RC-04.POE.PwrSup. EDK.2xMaglocks.Vestibule.SoftInterlock. D1LockedD2Unlocked		
Dwg No:	Sheet 1	of 1
Date: 5-1-2019	Drawn By: David Tamarchenko	Version: 1.00.00
ISONAS PURE IP ACCESS CONTROL		4750 Walnut Street Suite 110 Boulder, CO 80301 www.isonas.com