

## DOOR HARDWARE

- (1) JUNCTION BOX BY OTHERS
- NOT USED
- VON DUPRIN QEL / FALCON MEL EXIT DEVICE (24 VDC)
- NOT USED
- NOT USED
- VON DUPRIN PS902 X 900-2RS
- VON DUPRIN REMOVABLE MULLION
- VON DUPRIN ELECTRIC POWER TRANSER
- SCHLAGE 623 SERIES REMOTE RELEASE BUTTON (OR EQUAL)

## GENERAL NOTES:

ALL LOW VOLTAGE WIRE TO RUN IN MINIMUM 3/4" CONDUIT OR INSIDE DRYWALL UNLESS NOTED OTHERWISE

ALL LOW VOLTAGE WIRE TO BE STRANDED WIRE
ALL GANG BOXES BY ELECTRICAL CONTRACTOR AS REQUIRED
ALL LOW VOLTAGE WIRING TO BE LABELED CLEARLY AT BOTH END

ALL MOUNTING HEIGHTS AS SHOWN
COORDINATE MOUNTING LOCATIONS WITH ELECTRICAL/ARCHITECTURAL PLANS

ANY DEVIATION FROM HARDWARE SPECIFIED IN SECTION 08710 WILL NEGATE ALL REQUIREMENTS SHOWN HEREIN AND REQUIRE NEW DRAWINGS BY OTHERS TO MATCH SUBSTITUTED HARDWARE


## DESCRIPTION: **OPERATIONAL**

DOORS NORMALLY CLOSED AND LOCKED ENTRY BY REMOTE PUSHBUTTON OR KEY OVER-RIDE FREE EGRESS AT ALL TIMES

## WIRE REQUIREMENTS

2/18 AWG STRANDED FOR EXIT DEVICE LATCH RETRACTION 4/18 AWG STRANDED FROM POWER SUPPLY TO J-BOX 2 WIRE FOR ELECTRIC EXIT DEVICE POWER 2 WIRES FOR PUSHBUTTON INPUT

\*\*ANY WIRE RUNS GREATER THAN 200 FEET VERIFY GAUGE WITH MANUFACTURER \*\*



Wiring Diagram Terms of Use: This information is for professional use only and is intended to be a guide for proper product application and specification. See specific product manuals for proper installation. Any installation should be performed by persons qualified to perform electrical work and in compliance with applicable codes, rules, regulations and orders. Allegion reserves the right to change or modify the information herein without notice. No warranties, express or implied, are provided by Allegion as a result of this information. Any and all use and reproduction of the information herein except for product application and specification is expressly forbidden.

Copyright 2021 Schlage Lock Company LLC.