



DOOR ELEVATION  
N.T.S.

### DOOR HARDWARE

- ① JUNCTION BOX BY OTHERS
- ② NOT USED
- ③ VON DUPRIN 6400 FSE ELECTRIC STRIKE
- ④ NOT USED
- ⑤ SCHLAGE L9456HD (OR EQUAL) X DM
- ⑥ LCN AUTO EQUALIZER AUTO DOOR OPERATOR
- ⑦ LCN SINGLE GANG BOX WIRED ACTUATORS
- ⑧ VON DUPRIN EPT10 POWER TRANSFER, ELECTRIC HINGE OR WIRE LOOP

### WIRE REQUIREMENTS

- 2/18 AWG STRANDED FOR ELECTRIC STRIKE
- 2/18 AWG STRANDED FOR MORTISE LOCK
- 2 WIRES FOR DEADBOLT MONITOR SWITCH
- 2/20 AWG STRANDED FROM ACTUATORS DIRECT TO SLOT 17/18. WIRE ONE LEG THROUGH DM SWITCH IN MORTISE LOCK
- 2/18 AWG STRANDED FROM SLOT 1/2 TO ELECTRIC STRIKE

\*\*ANY WIRE RUNS GREATER THAN 200 FEET VERIFY GAUGE WITH MANUFACTURER.\*\*

### GENERAL NOTES:

ALL LOW VOLTAGE WIRE TO RUN IN MINIMUM 3/4" CONDUIT OR INSIDE DRYWALL UNLESS NOTED OTHERWISE  
 ALL LOW VOLTAGE WIRE TO BE STRANDED WIRE  
 ALL GANG BOXES BY ELECTRICAL CONTRACTOR AS REQUIRED  
 ALL LOW VOLTAGE WIRING TO BE LABELED CLEARLY AT BOTH END  
 ALL MOUNTING HEIGHTS AS SHOWN  
 COORDINATE MOUNTING LOCATIONS WITH ELECTRICAL/ARCHITECTURAL PLANS  
 ANY DEVIATION FROM HARDWARE SPECIFIED IN SECTION 08710 WILL NEGATE ALL REQUIREMENTS SHOWN  
 HEREIN AND REQUIRE NEW DRAWINGS BY OTHERS TO MATCH SUBSTITUTED HARDWARE

### OPERATIONAL DESCRIPTION:

DOOR NORMALLY CLOSED AND UNLOCKED.  
 WHEN DEADBOLT IS ENGAGED, DM SWITCH SHUNTS ACTUATORS  
 INTERIOR / EXTERIOR ACTUATORS TO BE WIRED THROUGH DM SWITCH IN MORTISE LOCK SO THAT WHEN DEADLOCK IS ENGAGED  
 DOOR AUTO OPERATOR WILL NOT START OPENING CYCLE PREVENTING UNAUTHORIZED ACCESS  
 KEY OVER-RIDE WILL RETRACT DEADLATCH  
 FREE EGRESS AT ALL TIMES.

 <b>ALLEGION</b> <b>ELECTRIFIED</b> <b>ELEVATION</b> <b>DRAWINGS</b>	DRAWING: <b>ELEVATION DRAWING</b>	
	Drawn By: Jason Relyea DHT, DHC	Checked by:
	DATE: 03-15-2021	VERSION: 1
	SCALE: N.T.S.	REVISION:
		DRAWING NO: <b>2057</b>

Wiring Diagram Terms of Use: This information is for professional use only and is intended to be a guide for proper product application and specification. See specific product manuals for proper installation. Any installation should be performed by persons qualified to perform electrical work and in compliance with applicable codes, rules, regulations and orders. Allegion reserves the right to change or modify the information herein without notice. No warranties, express or implied, are provided by Allegion as a result of this information. Any and all use and reproduction of the information herein except for product application and specification is expressly forbidden.