

CATEGORY 5E OR 6 NETWORK CABLE
TO PoE NETWORK SWITCH

120 VAC

POWER SUPPLY

6/18 AWG STRANDED

JUNCTION BOX

NOTE:

ISONAS RC-04 PIGTAIL IS NOT PLENUM RATED.
PROVIDED METALLIC CONDUIT FROM J-BOX TO WALL

CEILING LINE

-4/18 AWG STRANDED FOR EACH EXIT DEVICE
-2/18 AWG STRANDED FOR DOOR POSITION
-2/18 AWG FROM DPDT RELAY TO ADO
-2/18 AWG FROM POWER SUPPLY TO ADO

120 VAC

P6
P10
P7

2/18 AWG STRANDED
TO AUTO EQUALIZER

SGL GANG
BOX REQ'D
PUSH SIDE
OF DOOR

2/18 AWG STRANDED
TO AUTO EQUALIZER

SGL GANG
BOX REQ'D
PULL SIDE
OF DOOR

ISONAS RC-04 PIGTAIL
25 FT OR AS REQ'D
CAT-5E OR 6 NETWORK
CABLE TO J-BOX

38"-42" AFF

FINISHED FLOOR

DOOR ELEVATION
N.T.S.

DOOR HARDWARE


- ① JUNCTION BOX BY OTHERS
- ② SCHLAGE DOOR POSITION SWITCH
- ③ VON DUPRIN QEL-RX OR FALCON MEL-RX EXIT DEVICE (24VDC)
- ④ ISONAS RC-04 CARD READER
- ⑤ VON DUPRIN EPT-10 POWER TRANSFER, ELECTRIFIED HINGE OR WIRE LOOP
- ⑥ LCN SENIOR SWING AUTOMATIC DOOR OPERATOR
- ⑦ VON DUPRIN PS902 X 900-2RS POWER SUPPLY (24VDC OUTPUT)
- ⑧ LCN SINGLE GANG BOX WIRED ACTUATORS
- ⑨ 12/24VDC DPDT THROW RELAY (MOUNT IN J-BOX)

GENERAL NOTES:

ALL LOW VOLTAGE WIRE TO RUN IN MINIMUM 3/4" CONDUIT OR INSIDE DRYWALL UNLESS NOTED OTHERWISE
ALL LOW VOLTAGE WIRE TO BE STRANDED WIRE
ALL GANG BOXES BY ELECTRICAL CONTRACTOR AS REQUIRED
ALL LOW VOLTAGE WIRING TO BE LABELED CLEARLY AT BOTH END
ALL MOUNTING HEIGHTS AS SHOWN
COORDINATE MOUNTING LOCATIONS WITH ELECTRICAL/ARCHITECTURAL PLANS
ANY DEVIATION FROM HARDWARE SPECIFIED IN SECTION 08710 WILL NEGATE ALL REQUIREMENTS SHOWN
HEREIN AND REQUIRE NEW DRAWINGS BY OTHERS TO MATCH SUBSTITUTED HARDWARE

OPERATIONAL DESCRIPTION:

DOOR NORMALLY CLOSED AND LOCKED.
ENTRY BY VALID CREDENTIAL AT CARD READER OR BY KEY OVER-RIDE.
RX MOTION SENSOR SHUNTS DOOR FORCED OPEN IN ACCESS CONTROL SYSTEM.
INTERIOR ACTUATOR TO START OPENING CYCLE (UNLESS ADO IS POWERED OFF)
EXTERIOR ACTUATOR WIRED IN SERIES THROUGH ACCESS CONTROL SYSTEM AUX RELAY SUCH THAT ON VALID CARD OR TIME ZONE CONTROL ACTUATOR CAN BE PRESSED TO START OPENING CYCLE.
KEY OVER-RIDE WILL CAUSE DOOR FORCED EVENT IN ACCESS CONTROL SYSTEM.
FREE EGRESS AT ALL TIMES.

 ALLEGION ELECTRIFIED ELEVATION DRAWINGS	DRAWING: ELEVATION DRAWING	
	Drawn By: Jason Relyea DHT, DHC	Checked by:
DATE: 11-15-2021	VERSION: 1	DRAWING NO: 9027
SCALE: N.T.S.	REVISION:	

Wiring Diagram Terms of Use: This information is for professional use only and is intended to be a guide for proper product application and specification. See specific product manuals for proper installation. Any installation should be performed by persons qualified to perform electrical work and in compliance with applicable codes, rules, regulations and orders. Allegion reserves the right to change or modify the information herein without notice. No warranties, express or implied, are provided by Allegion as a result of this information. Any and all use and reproduction of the information herein except for product application and specification is expressly forbidden.