


Don't forget to calculate maximum current consumption of all equipment

Do not exceed 600ma

An auxiliary power supply may be required depending on locking hardware



**RC-03.PoE.DoorOpenOutput.  
LocalAlarm.CredentialReset**

Dwg No:	Sheet 1 of 1
Date: 4-20-20	Drawn By: David Tamarchenko
	Version: 1.00.00

**ISONAS**  
PURE IP ACCESS CONTROL

4750 Walnut Street Suite 110  
Boulder, CO 80301  
www.isonas.com