



NOTES:  
 1) ALL LOW VOLTAGE WIRING TO BE STANDARD, MULTI-CONDUCTOR CORD CODED WITHOUT SPLICES.  
 2) WIRING TO CONFORM TO APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL CODES.  
 3) REFER TO SPECIFIC PRODUCT INSTALLATION INSTRUCTIONS FOR SPECIFIC WIRING REQUIREMENTS.  
 4) THIS DRAWING IS FOR GRAPHICAL REPRESENTATION OF PRODUCTS DETAILED IN THE HARDWARE SET ONLY.  
 5) # CONDUCTOR COUNT TO BE DETERMINED BY ACCESS CONTROL PANEL PROVIDER.

OPERATION:  
 BLACKBOARD SA3000 SYSTEM WILL SUPPORT UP TO EIGHT AD300. IF PLENUM RATED CABLE IS REQUIRED USE BELDEN 88103 OR EQUIVALENT.  
 UL 294 POWER SUPPLIES USED SHOULD NOT BOND EARTH GROUND TO SIGNAL GROUND.  
 WIRING SHOWN REFLECTS WIRING FROM SA3000 TO AD-300 ONLY. ADDITIONAL WIRING IS REQUIRED THAT WILL NOT BE SHOWN HERE.  
 GROUND SHIELD ON BELDEN 9843 RS485 LINE AT ONE LOCATION ONLY.

NOTE: CONFIGURATION HAS NOT BEEN TESTED BY ALLEGION BUT HAS BEEN REVIEWED AND APPROVED BY BLACKBOARD  
 DATE DRAWN 02-20-15 REVISION DATE 02-20-15 APPROVED BY DAN DREWNOWSKI

TITLE:  
**BLACKBOARD SA3000 WITH AD-300'S**

**ALLEGION™**

copyright 2015  
 DWG NO: 110789  
 DRAWN/CHECKED BY: BRENDA DIVE 02-20-15  
 REV A