



READER CONFIGURATION

	CLK/DATA	WIEGAND		P3/P4
	SW1	SW1	SW2	1-2
1	OFF	ON	ON	
2	ON	ON	OFF	
3	ON	ON	OFF	
4	ON	ON	OFF	
5	X	X	OFF	
6	X	X	OFF	
7	ON	ON	OFF	
8	ON	ON	OFF	

5375 MAXI PROX TO SIGNAL FSE eSTRIKE TO RELEASE THROUGH SES CT5000.
 FIRE ALARM TO DISABLE 5375 MAXI PROX FUNCTION AND CAUSE FSE eSTRIKE TO REMAIN LOCKED.
 IF NOT A FIRE RATED OPENING AND FIRE ALARM IS NOT REQUIRED, OMIT FA BOARD IN PS902-FA POWER SUPPLY.

CREATOR: BRENDA DOVE 05/16/12	TITLE: CT5000/5375 MAXI PROX WITH FSE eSTRIKE	515122CT5000
APPROVED: MANFRED STEFFES 05/16/12		DRAWING NO.