


MTK15 INTERIOR OR SCAN II MOTION SENSOR TO SIGNAL MAGLOCK TO RELEASE THROUGH SES CT5000.

FIRE ALARM TO RELEASE MAGLOCK AND DISARM MTK15 AND CT5000.

SET PS902-FA VOLTAGE TO 12VDC.

ALL CONNECTIONS SHOWN MADE IN CT5000 ENCLOSURE.

| | | |
|---|---|---|
| CREATOR: BRENDA DOVE 02/22/12 | TITLE: CT5000/MTK15 with KEYPAD and MAGLOCK | 222123CT5000 Rev 2 |
| APPROVED: TODD GINTER 02/29/12 | | 10/11/12 |