



Important – Read This First

- Always refer to manufacturer instructions, this drawing is a recommendation and site characteristics vary.
- When utilizing 12vdc from a PoE powered RC-04 verify power calculation to ensure enough power is available for all devices.
- Some adjustment of the timing will be necessary by adjusting the potentiometers, installing the device at default values will result in errors.

| | | |
|---|--------------------------------|---|
| RC-04.POE.Strike.REX.DSM.ADA-CADS1 | | |
| Dwg No: | Sheet 1 | of 1 |
| Date: 10-10-2017 | Drawn By: David Tamarchenko | Version: 1.00.00 |
| ISONAS PURE IP ACCESS CONTROL | | 4750 Walnut Street Suite 110 Boulder, CO 80301 www.isonas.com |