



Always Check with the Local Authority having Jurisdiction (AHJ) before implementing stairwell access control.

Electrified Locks used in stairwells must be fail safe, unlock on fire alarm and/or power loss, or be controlled by a key switch at the main fire alarm panel annunciator.

When the locking hardware is in an unlocked condition it MUST still maintain latch point. I.e. no maglocks or electric strikes.

Some jurisdictions have restrictions on the number of total stories that building may have while locking stairwells.

Some jurisdictions have restrictions on how many floors in a row may be locked in a stairwell. For example in Denver every fifth floor must not be locked to allow people enter back into the building if there is a problem with the stairwell.

RC-04.PwrSup.EDK.Stairwell.Code

Dwg No:	Sheet 1	of 1
Date: 5-9-18	Drawn By: David Tamarchenko	Version: 1.00.00

ISONAS
PURE IP ACCESS CONTROL
4750 Walnut Street Suite 110
Boulder, CO 80301
www.isonas.com