




RS-485 integration for AD-300 hardwired devices



1 In order to have a UL Listed configuration a UL294 12VDC power supply must be used instead of PoE

2 2 AD-300 can be PoE (Power Over Ethernet) the remaining 6 AD-300 will be powered from an external 12/24VDC power supply